

# PUBLIC POOL DAILY RECORDS

Date: \_\_\_\_\_

Daily Inspection (½ hour prior to opening public pool)								
	Time	Operator's Initial		Time	Operator's Initial			
Emergency Telephone			Spine Board					
Ground Fault Circuit Interrupter			First Aid Kit					
Non-conducting Reaching Pole			2 Health Regulation Signs					
2 Buoyant Throwing Aids			Unsupervised sign <i>(If applicable)</i>					
Water Chemistry								
<i>To be tested ½ hour prior to opening pool and then every 2 hours while pool is open. If Automatic Sensing Device is used, test water chemistry ½ hour prior to opening pool and one more time while it is open.</i>								
	½ hr. Before opening	Time am/pm	Time am/pm	Time am/pm	Time am/pm	Time am/pm	Time am/pm	Time am/pm
<b>Free Available Chlorine/Bromine</b> <i>(minimum 0.5 mg/L - unstabilized) (minimum 1.0 mg/L - stabilized)</i>								
<b>Total Chlorine/Bromine</b> <i>(minimum 2 mg/L)</i>								
<b>pH</b> <i>(7.2 – 7.8)</i>								
<b>Total Alkalinity</b> <i>(minimum 80 mg/L)</i>								
<b>Water Clarity</b> <i>(black disc visibility)</i>								
<b>Operator's Initials</b>								
Other Records								
<b>Number of bathers</b>						Signature		
<b>Water meter reading</b>	Ensure minimum 20L/bather of make-up water is added to the pool daily					Signature		
<b>Cyanuric Acid</b>	If used, to be tested once per week and should not exceed 60 mg/L					Signature		
<b>Inspection of water outlet covers</b>	At least once per month					Signature		
<b>Emergencies, rescues, equipment breakdown, back washing etc.</b>	Record the time and details of what happened					Signature		